### Report of the HBHE irradiation test at CERN

Tugba Karakaya





- The Charm Facility
- Cabling
- Transporting cable-holder chain and the rack
- PRBS results
- PRBS Error Rate per high energy eq. fluency and per hour

## The CHARM facility

- CERN East Hall in bldg. 157, on the beam line T8
  - 3 different target types are used:

Copper, Aluminium sieve and Aluminium

• 24 GeV proton beam

## The CHARM Facility

#### Мар



### Cabling in the radiation area CHARM Facility





Single Mode duplex finer



6 Multi Mode fiber



ethernet cable

 Cables for patch-panel and for the backplane of front end





end of the network cable



end of the power cable

### Cabling in the preparation room CHARM Facility



4 HE MM fibers





HE power cable





6 HF MM Cables



# Testing the cabling with cable-holder chain





#### FE Controler(BE Crate)

#### Patch panel and FE Crate

Cable-holder chain in the buffer zone outside the controlled area



 Cable-holder chain with some protection and labels on both ends (which is the FE end and which is the panel end).



# Moving the cable-holder chain from buffer zone to the radiation area



## Our Setup in the irradiation area CHARM



 pictures of our setup just before it was moved to the connection point with radiation measurement electronics (RadMon)

## **Rack Transportation**







## The results of a bit error rate detection in the ngFEC - ngCCM communication using 23 Bits PRBS in the irradiation test

- We have not observed any PRBS errors during the dry run using both Finisar FTLX1370W3BTL and Finisar FTLX1471D3BCL SFP+ modules.
  - We used the FTLX1370W3BTL during the irradiation test
- PRBS errors in the ngCCM -> ngFEC path were proportional to the radiation dose (Copper > Aluminium > Aluminium sieve) as expected
  - Error did not increase constantly, but rather small bursts in short time intervals.
  - With the copper target, the error rate increased as much as ~1000 error patterns per two minutes (script's time resolution).
- We observed errors on the ngFEC -> ngCCM path only in four instances: Three of them are due to restart of the ngFEC FC7.

# PRBS Error Rate per high energy hadron eq. fluence and per hour

PRBS Error Pattern Rate

