

# Status update: ARES Data Analysis and LUXE320 Detector

Antonios Athanassiadis, Karsten Gadow, Louis Helary, Luke Hendriks, Ruth Magdalena Jacobs, Jenny List, Evan Ranken, Stefan Schmitt, Ivo Schulthess, Matthew Wing


20.02.2024

# ARES Testbeam Data Analysis

## Charge Scan

- Shows linear response for low charges
- Analysis of non-linearity for high charges ongoing
  - Charge overestimation?


Light yield measured in one straw for different angles



# ARES Testbeam Data Analysis


## Charge Scan

- Shows linear response for low charges
- Analysis of non-linearity for high charges ongoing  
→ Charge overestimation?



## Position Scan


- Horizontal beam profile measurable
- Different heights due to straw position (front or back row) and SiPM model (blue vs. green)
- Offset origins most likely from direct particle hits in the SiPMs



# ARES Testbeam Data Analysis


## Charge Scan

- Shows linear response for low charges
- Analysis of non-linearity for high charges ongoing  
→ Charge overestimation?



## Position Scan

- Horizontal beam profile measurable
- Different heights due to straw position (front or back row) and SiPM model (blue vs. green)
- Offset origins most likely from direct particle hits in the SiPMs



# LUXE320 Detector

## Status

- Material lists for SLAC setup (Antonios)
- First CAD drawing of detector with 32 straws and Daniels PCB (2 times 2 rows à 8 straws) in progress (Karsten, Daniel, Antonios)
- Geant4 simulation work in progress (Evan, Antonios)
- ESTA application confirmed (Ivo, Antonios)
- EPICS successfully installed for the first time (Luke)
- 32 channel digitizer, PCB & SiPMs ordered
- Further discussions with SLAC necessary for beam time schedule  
→ Earlier than June probably not feasible for us

